Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number - 12490

Pollution Monitoring - Annual Air Monitoring data

Sample Period - December 2015 - November 2016

Sample Location	Data Sort	Carbon Dioxide mg/m3	Dry Gas Density kg/m3	Moisture Content %	Molecular Weight of Stack Gases g/g	Oxygen mg/m3	Temperature 0C	Velocity m/sec	Volumetric Flow rate	Sampling / Publishing Dates	
Sample Point:	Average	3.50	1.31	6.80	29.30	14.90	527.00	38.00	1100.00	Date Data Sampled -	18/10/2016
EPA Identification No. 1	Minimum	3.40	-	-	-	14.80	-	-	-	Date Data Available -	11/11/2016
Turbine Stack 1	Maximum	3.50	-	-	-	14.90	-	-	-	Date Data Published -	20/11/2016
Sample Point:	Average	3.50	1.31	6.50	29.30	14.90	527.00	42.00	1300.00	Date Data Sampled -	18/10/2016
EPA Identification No. 2	Minimum	3.40	-	-	-	14.90	-	-	-	Date Data Available -	11/11/2016
Turbine Stack 2	Maximum	3.50	-	-	-	14.90	-	-	-	Date Data Published -	20/11/2016
Sample Point:	Average	3.50	1.31	5.50	29.30	14.80	524.00	40.00	1200.00	Date Data Sampled -	19/10/2016
EPA Identification No. 3	Minimum	3.40	-	-	-	14.70	-	-	-	Date Data Available -	11/11/2016
Turbine Stack 3	Maximum	3.60	-	-	-	14.90	-	-	-	Date Data Published -	20/11/2016
Sample Point:	Average	3.10	1.30	6.40	29.20	15.50	527.00	40.00	1200.00	Date Data Sampled -	19/10/2016
EPA Identification No. 4	Minimum	3.10	-	-	-	15.40	-	-	-	Date Data Available -	11/11/2016
Turbine Stack 4	Maximum	3.20	-	-	-	15.50	-	-	-	Date Data Published -	20/11/2016
Environmental Licence Concentration Limits -											
Percentile:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Limits:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		