

Environment Protection Licence Licensee -

Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number -

12490

Pollution Monitoring -

Nitrogen Oxides

REPORTING PERIOD

1 Dec 18 - 30 Nov 19



Sample Location	Data Sort	Dec-18	Jan-19	Feb-19	Mar-19	Apr-19	May-19	Jun-19	Jul-19	Aug-19	Sep-19	Oct-19	Nov-19	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	26	16	18	24	27	26	28	28	28	28	26	27	25	mg/m3	-	-
EPA Identification No. 1	Minimum	9	6	7	8	23	12	23	23	23	23	9	8	6	mg/m3	-	-
Unit 11	Maximum	47	42	38	47	38	51	51	50	50	51	51	51	51	mg/m3	51	100
Sample Point:	Average	30	19	20	26	0	26	30	29	29	29	29	29	25	mg/m3	-	-
EPA Identification No. 2	Minimum	25	8	8	9	0	11	24	25	26	11	10	9	0	mg/m3	-	-
Unit 12	Maximum	44	48	50	48	0	51	51	50	51	50	50	51	51	mg/m3	51	100
Sample Point:	Average	26	17	29	17	28	26	30	30	0	27	25	25	23	mg/m3	-	-
EPA Identification No. 3	Minimum	8	7	7	8	24	10	27	27	0	10	9	7	0	mg/m3	-	-
Unit 13	Maximum	43	46	45	37	42	46	47	45	0	51	51	46	51	mg/m3	51	100
Sample Point:	Average	24	15	14	17	28	26	26	26	27	27	25	33	24	mg/m3	-	-
EPA Identification No. 4	Minimum	7	7	7	8	24	10	21	23	23	24	22	11	7	mg/m3	-	-
Unit 14	Maximum	41	43	37	36	43	47	41	36	41	42	41	47	47	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Note: "-" indicates no Unit run for reporting period		
Date Data Downloaded		3/01/2019	20/02/2019	20/03/2019	19/04/2019	21/05/2019	13/06/2019	8/07/2019	5/08/2019	2/09/2019	7/10/2019	4/11/2019	3/12/2019				
Date Data Published		0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900				