

Environment Protection Licence Licensee -

Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number -

12490

Pollution Monitoring -

Nitrogen Oxides

REPORTING PERIOD

1 Dec 19 - 30 Nov 20



Sample Location	Data Sort	Dec-19	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	23	22	21	29	0	27	0	0	0	25	21	25	16	mg/m3	-	-
EPA Identification No. 1	Minimum	8	8	8	25	0	24	0	0	0	22	7	17	0	mg/m3	-	-
Unit 11	Maximum	50	50	46	47	0	43	0	0	0	41	42	38	50	mg/m3	51	100
Sample Point:	Average	24	24	25	31	35	27	0	0	0	0	30	29	19	mg/m3	-	-
EPA Identification No. 2	Minimum	9	9	8	28	28	24	0	0	0	0	23	24	0	mg/m3	-	-
Unit 12	Maximum	50	50	49	41	49	40	0	0	0	0	46	48	50	mg/m3	51	100
Sample Point:	Average	26	23	19	28	0	28	0	0	25	24	28	30	19	mg/m3	-	-
EPA Identification No. 3	Minimum	6	6	6	22	0	24	0	0	23	20	9	21	0	mg/m3	-	-
Unit 13	Maximum	44	47	46	40	0	38	0	0	37	40	46	47	47	mg/m3	51	100
Sample Point:	Average	25	25	25	29	29	28	0	32	29	27	31	28	26	mg/m3	-	-
EPA Identification No. 4	Minimum	8	7	7	24	26	25	0	24	27	24	11	8	0	mg/m3	-	-
Unit 14	Maximum	42	47	43	40	40	41	0	44	38	37	49	48	49	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	<b>Note:</b> "-" indicates no Unit run for reporting period		
Date Data Downloaded		6/01/2020	2/02/2020	5/03/2020	6/04/2020	6/05/2020	2/06/2020	3/07/2020	8/08/2020	2/09/2020	4/10/2020	4/11/2020	1/12/2020				
Date Data Published		0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900	0/01/1900				