

Environment Protection Licence Licensee -
 Environment Protection Licence Number -
 Pollution Monitoring -
 Sample Period -

Origin Energy Uranquinty Power PTY LTD
 12490
 Water Sampling
 September 2017 - November 2018



Sample Location	Date Sampled	Sample Parameters, Units Of Measure & Licence Limit Conditions					Analysis	Sample Reason	Date Data Obtained	Date Data Published
		Chloride (mg/l) Licence Limit - N/A	pH (pH) Licence Limit - N/A	Conductivity (us/cm) Licence Limit - 100 percentile - 800	Sodium (mg/l) Licence Limit - N/A	Total Suspended Solids (mg/l) Licence Limit - N/A				
EPA Identification No. 7 Discharge to Land	07/09/2017	77.7	8.00	502	34.5	16	CSU EAL	Monthly Irrigation		
EPA Identification No. 7 Discharge to Land	07/09/2017	0	8.50	518	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	12/09/2017	0	8.90	511	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	18/09/2017	0	8.75	502	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	27/09/2017	0	8.54	520	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	03/10/2017	0	8.86	533	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	10/10/2017	0	8.89	484	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	17/10/2017	0	9.00	480	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	02/11/2017	0	8.95	469	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	02/11/2017	71	8.60	458	43.3	13	CSU EAL	Monthly Irrigation		
EPA Identification No. 7 Discharge to Land	07/11/2017	0	8.10	456	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	15/11/2017	0	8.30	444	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	28/11/2017	0	8.10	388	0	0	Onsite	Weekly Irrigation		
EPA Identification No. 7 Discharge to Land	29/11/2017	62.6	7.50	398	36.2	4	CSU EAL	Monthly Irrigation		
EPA Identification No. 7 Discharge to Land	05/12/2017	0	7.72	333	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	13/12/2017	45.7	8	330	30.5	3	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	14/12/2017	0	8.38	358	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	27/12/2017	0	7.94	349.4	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	18/01/2018	46.6	8.3	326	26.6	<2	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	23/01/2018	0	8.25	339	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	31/01/2018	0	8.10	292	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	05/02/2018	0	8.35	308.4	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	14/02/2018	0	8.10	310	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	20/02/2018	0	8.30	307	0	0	On site	Weekly irrigation		

Environment Protection Licence Licensee -
 Environment Protection Licence Number -
 Pollution Monitoring -
 Sample Period -

Origin Energy Uranquinty Power PTY LTD
 12490
 Water Sampling
 September 2017 - November 2018



Sample Location	Date Sampled	Sample Parameters, Units Of Measure & Licence Limit Conditions					Analysis	Sample Reason	Date Data Obtained	Date Data Published
		Chloride (mg/l) Licence Limit - N/A	pH (pH) Licence Limit - N/A	Conductivity (us/cm) Licence Limit - 100 percentile - 800	Sodium (mg/l) Licence Limit - N/A	Total Suspended Solids (mg/l) Licence Limit - N/A				
EPA Identification No. 7 Discharge to Land	21/02/2018	41.9	8.00	304	31.7	9	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	27/02/2018	0	8.90	322	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	05/03/2018	0	8.87	235	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	13/03/2018	0	8.01	237	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	22/03/2018	32.7	8.10	232	20	19	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	22/03/2018	0	8.30	241	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	26/03/2018	0	7.57	243	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	07/04/2018	0	8.10	250	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	16/04/2018	0	8.54	251	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	20/04/2018	24.7	8.1	253	23.8	15	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	24/04/2018	0	8.10	264	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	30/04/2018	0	8.20	268	0	0	On site	Weekly irrigation		

Environment Protection Licence Licensee -
 Environment Protection Licence Number -
 Pollution Monitoring -
 Sample Period -

Origin Energy Uranquinty Power PTY LTD
 12490
 Water Sampling
 September 2017 - November 2018



Sample Location	Date Sampled	Sample Parameters, Units Of Measure & Licence Limit Conditions					Analysis	Sample Reason	Date Data Obtained	Date Data Published
		Chloride (mg/l) Licence Limit - N/A	pH (pH) Licence Limit - N/A	Conductivity (us/cm) Licence Limit - 100 percentile - 800	Sodium (mg/l) Licence Limit - N/A	Total Suspended Solids (mg/l) Licence Limit - N/A				
EPA Identification No. 7 Discharge to Land	08/05/2018	0	8.10	260	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	15/05/2018	56	8.1	254	20.8	9	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	12/06/2018	0	8.30	260	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	14/06/2018	20.7	8	246	35.8	9	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	15/06/2018	0	8.15	245	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	18/06/2018	0	8.08	252	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	25/06/2017	0	8.31	242.5	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	05/07/2018	0	8.28	241	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	09/07/2018	0	8.17	243	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	19/07/2018	0	8.10	244	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	26/7/2018	30.4	8.40	245	19	2	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	15/08/2018	0	8.90	232	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	15/08/2018	29.6	8.80	233	18	4	CSU EAL	Monthly Irrigation		
EPA Identification No. 7 Discharge to Land	20/08/2018	0	8.00	230.6	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	04/09/2018	0	8.40	232	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	10/09/2018	0	8.30	220	0	0	On site	Weekly irrigation		

Environment Protection Licence Licensee -

Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number -

12490

Pollution Monitoring -

Water Sampling

Sample Period -

September 2017 - November 2018



Sample Location	Date Sampled	Sample Parameters, Units Of Measure & Licence Limit Conditions					Analysis	Sample Reason	Date Data Obtained	Date Data Published
		Chloride (mg/l) Licence Limit - N/A	pH (pH) Licence Limit - N/A	Conductivity (us/cm) Licence Limit - 100 percentile - 800	Sodium (mg/l) Licence Limit - N/A	Total Suspended Solids (mg/l) Licence Limit - N/A				
EPA Identification No. 7 Discharge to Land	18/09/2018	26.5	8.90	223	19.1	16	CSU EAL	Monthly irrigation		
EPA Identification No. 7 Discharge to Land	19/09/2018	0	8.80	227.3	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	24/09/2018	0	8.80	230	0	0	On site	Weekly irrigation		
EPA Identification No. 7 Discharge to Land	03/10/2018	29.1	9.00	226	19.8	24	CSU EAL	Monthly irrigation		