

Environment Protection Licence Licensee -
 Environment Protection Licence Number -
 Pollution Monitoring -
 Sample Period -

Origin Energy Uranquinty Power PTY LTD
 12490
 Nitrogen Oxides
 December 2013 - November 2014



Sample Location	Data Sort	Dec-12	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	30	27	31	30	34	30	29	29	26	24	34	32	29	mg/m3	-	-
EPA Identification No. 1	Minimum	19	14	27	27	31	3	24	10	9	1	4	14	1	mg/m3	-	-
Turbine Stack 1	Maximum	49	46	43	34	46	48	50	50	49	51	48	48	51	mg/m3	51	100
Sample Point:	Average	19	16	20	-	27	29	25	27	24	23	22	24	23	mg/m3	-	-
EPA Identification No. 2	Minimum	1	1	10	-	12	13	10	11	10	7	1	11	1	mg/m3	-	-
Turbine Stack 2	Maximum	31	24	22	-	31	33	33	33	33	51	32	34	51	mg/m3	51	100
Sample Point:	Average	8	11	18	-	16	26	28	32	26	26	20	28	22	mg/m3	-	-
EPA Identification No. 3	Minimum	1	1	4	-	3	1	4	9	5	1	2	12	1	mg/m3	-	-
Turbine Stack 3	Maximum	27	32	85	-	44	50	46	45	48	49	46	51	85	mg/m3	51	100
Sample Point:	Average	17	13	28	-	30	28	24	24	22	22	31	35	25	mg/m3	-	-
EPA Identification No. 4	Minimum	4	1	21	-	23	7	7	12	9	5	8	2	1	mg/m3	-	-
Turbine Stack 4	Maximum	24	38	46	-	47	49	44	51	48	50	51	51	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Note: "-" indicates no Unit run for reporting period		
Date Data Downloaded		15/01/2014	15/01/2014	10/02/2014	3/03/2014	9/05/2014	23/06/2014	2/07/2014	5/08/2014	22/09/2014	30/10/2014	9/12/2014	9/12/2014				
Date Data Published		31/01/2014	31/01/2014	30/03/2014	18/03/2014	10/05/2014	30/06/2014	16/07/2014	20/07/2014	14/10/2014	14/11/2014	16/12/2014	16/12/2014				