Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number - 12490

Pollution Monitoring - Annual Air Monitoring data

Sample Period - December 2013 - November 2014

Sample Location	Data Sort	Carbon Dioxide mg/m3	Dry Gas Density kg/m3	Moisture Content %	Molecular Weight of Stack Gases g/g	Oxygen mg/m3	Temperature OC	Velocity m/sec	Volumetric Flow rate	Sampling / Publishing Dates	
Sample Point:	Average	3.60	1.31	5.00	29.30	15.00	530.85	40.00	1200.00	Date Data Sampled -	5/11/2014
EPA Identification No. 1	Minimum	3.50	-	-	-	14.80	-	-	-	Date Data Available -	14/11/2014
Turbine Stack 1	Maximum	3.40	-	-	-	15.10	-	-	-	Date Data Published -	16/12/2014
Sample Point:	Average	3.60	1.31	5.70	29.30	15.00	522.85	39.00	1200.00	Date Data Sampled -	5/11/2014
EPA Identification No. 2	Minimum	3.50	-	-	-	15.00	-	-	-	Date Data Available -	14/11/2014
Turbine Stack 2	Maximum	3.60	-	-	-	15.10	-	-	-	Date Data Published -	16/12/2014
Sample Point:	Average	3.70	1.31	6.30	29.30	14.90	524.85	41.00	1200.00	Date Data Sampled -	6/11/2014
EPA Identification No. 3	Minimum	3.60	-	-	-	14.80	-	-	-	Date Data Available -	14/11/2014
Turbine Stack 3	Maximum	3.70	-	-	-	14.90	-	-	-	Date Data Published -	16/12/2014
Sample Point:	Average	3.60	1.31	6.60	29.30	15.00	524.85	43.00	1300.00	Date Data Sampled -	6/11/2014
EPA Identification No. 4	Minimum	3.50	-	-	-	14.90	-	-	-	Date Data Available -	14/11/2014
Turbine Stack 4	Maximum	3.70	-	-	-	15.10	-	-	-	Date Data Published -	16/12/2014
Environmental Licence Concentration Limits -											
Percentile:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Limits:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		