Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number - 12490

Pollution Monitoring - Annual Air Monitoring data

Sample Period - December 2014 - November 2015

Sample Location	Data Sort	Carbon Dioxide %	Dry Gas Density Kg/m3	Moisture Content %	Molecular Weight of Stack Gases g/g mole	Oxygen mg/m3	Temperature 0C	Velocity m/sec	Volumetric Flow rate m3	Sampling / Publishing Dates	
Sample Point:	Average	3.30	1.30	4.70	29.30	15.00	530.00	40.00	1200.00	Date Data Sampled -	11/11/2015
EPA Identification No. 1	Minimum	3.20	-	-	-	15.00	-	-	-	Date Data Available -	19/11/2015
Turbine Stack 1	Maximum	3.30	-	-	-	15.10	-	-	-	Date Data Published -	30/11/2015
Sample Point:	Average	3.30	1.30	5.00	29.20	15.00	536.00	40.00	1200.00	Date Data Sampled -	11/11/2015
EPA Identification No. 2	Minimum	3.20	-	-	-	14.90	-	-	-	Date Data Available -	19/11/2015
Turbine Stack 2	Maximum	3.40	-	-	-	15.10	-	-	-	Date Data Published -	30/11/2015
Sample Point:	Average	3.30	1.31	5.10	29.20	15.00	534.00	40.00	1200.00	Date Data Sampled -	11/11/2015
EPA Identification No. 3	Minimum	3.30	-	-	-	15.00	-	-	-	Date Data Available -	19/11/2015
Turbine Stack 3	Maximum	3.40	-	-	-	15.00	-	-	-	Date Data Published -	30/11/2015
Sample Point:	Average	3.20	1.31	5.10	29.20	15.10	522.00	40.00	1200.00	Date Data Sampled -	11/11/2015
EPA Identification No. 4	Minimum	3.20	-	-	-	15.10	-	-	-	Date Data Available -	19/11/2015
Turbine Stack 4	Maximum	3.30	-	-	-	15.20	-	-	-	Date Data Published -	30/11/2015
Environmental Licence Concentration Limits -											
Percentile:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Limits:		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		