Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number - 12490

Pollution Monitoring - Water Sampling

Sample Period - November 23 - December 24

Sample Location	Date Sampled	Sample Parameters, Units Of Measure & Licence Limit Conditions					Analysis	Sample Reason	Date Data Obtained	Date Data Published
		Chloride (mg/l) Licence Limit - N/A	pH (pH) Licence Limit - N/A	Conductivity (us/cm) Licence Limit - 100 percentile - 800	Sodium (mg/l) Licence Limit - N/A	Total Suspended Solids (mg/l) Licence Limit - N/A				
EPA Identification No. 7 Discharge to Land	23/12/2023	10.5	6.9	114	6.79	5	Charles Sturt	Monthly	1/02/2024	5/02/2024
EPA Identification No. 7 Discharge to Land	5/04/2024	3.6	8.2	191	8.37	<2	Charles Sturt	Monthly	22/05/2024	22/05/2024
EPA Identification No. 7 Discharge to Land	2/04/2024	-	8.78	128.5	-	-	Site	Weekly (irrigation)	2/04/2024	22/05/2024
EPA Identification No. 7 Discharge to Land	24/04/2024	-	9	146	-	-	Site	Weekly (irrigation)	24/04/2024	22/05/2024
EPA Identification No. 7 Discharge to Land	2/05/2024	8.5	8.8	123	8.33	<2	Charles Sturt	Monthly	10/06/2024	10/06/2024
EPA Identification No. 7 Discharge to Land	2/06/2024	5.9	7.5	114	7.19	9	Charles Sturt	Monthly	19/07/2024	22/07/2024
EPA Identification No. 7 Discharge to Land	12/07/2024	4.1	8.6	116	6.91	9	Charles Sturt	Monthly	16/08/2024	19/08/2024
EPA Identification No. 7 Discharge to Land	27/09/2024	11.4	7.7	225	19.9	14	Charles Sturt	Monthly	31/10/2024	31/10/2024