Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
Environment Protection Licence Number - 12490
Pollution Monitoring - Nitrogen Oxides

REPORTING PERIOD November 22 - November 23

Sample Location	Data Sort	Dec-22	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	0	38	35	24	24	31	34	31	31	31	35	30	29	mg/m3	-	-
EPA Identification No. 1	Minimum	0	14	16	9	7	11	26	17	10	5	31	7	0	mg/m3	-	-
Unit 11	Maximum	0	49	48	51	45	51	48	50	51	51	47	51	51	mg/m3	51	100
Sample Point:	Average	0	24	23	29	17	28	31	30	30	31	34	26	25	mg/m3	-	-
EPA Identification No. 2	Minimum	0	7	8	7	7	7	29	7	9	7	19	6	0	mg/m3	-	-
Unit 12	Maximum	50	50	49	41	49	40	0	0	0	0	45	46	50	mg/m3	51	100
Sample Point:	Average	33	21	27	25	22	27	30	28	28	30	28	25	27	mg/m3	-	-
EPA Identification No. 3	Minimum	27	1	2	6	7	7	9	8	8	12	23	6	1	mg/m3	-	-
Unit 13	Maximum	38	43	47	47	48	44	46	44	45	50	51	44	51	mg/m3	51	100
Sample Point:	Average	0	22	27	25	22	24	32	29	27	29	30	25	24	mg/m3	-	-
EPA Identification No. 4	Minimum	0	6	8	4	5	4	9	7	8	8	24	9	0	mg/m3	-	-
Unit 14	Maximum	0	38	46	40	40	50	41	45	42	41	46	51	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		1/01/2023	1/02/2023	1/03/2023	1/04/2023	1/05/2023	1/06/2023	1/07/2023	1/08/2023	1/09/2022	1/10/2023	1/11/2023	1/12/2023		*"-" indicates no Unit run for reporting period*		
Date Data Published		15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024	15/01/2024				