Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
Environment Protection Licence Number - 12490
Pollution Monitoring - Nitrogen Oxides

REPORTING PERIOD 1 DEC 25 - 30 NOV 26

Sample Location	Data Sort	Dec-25	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	20	26	24	27	0	27	26	0	0	0	0	0	21	mg/m3	-	-
EPA Identification No. 1	Minimum	5	8	7	22	0	23	22	0	0	0	0	0	0	mg/m3	-	-
Unit 11	Maximum	42	41	45	48	0	37	45	0	0	0	0	0	48	mg/m3	51	100
Sample Point:	Average	18	31	25	40	0	29	25	0	0	0	0	0	24	mg/m3	-	-
EPA Identification No. 2	Minimum	6	10	8	38	0	26	8	0	0	0	0	0	0	mg/m3	-	-
Unit 12	Maximum	49	41	49	41	0	33	39	0	0	0	0	0	49	mg/m3	51	100
Sample Point:	Average	19	30	25	26	0	24	25	0	0	0	0	0	21	mg/m3	-	-
EPA Identification No. 3	Minimum	6	19	20	22	0	8	8	0	0	0	0	0	0	mg/m3	-	-
Unit 13	Maximum	44	41	42	33	0	39	42	0	0	0	0	0	44	mg/m3	51	100
Sample Point:	Average	20	28	23	28	0	31	28	0	0	0	0	0	22	mg/m3	-	-
EPA Identification No. 4	Minimum	5	8	7	24	0	27	9	0	0	0	0	0	0	mg/m3	-	-
Unit 14	Maximum	42	40	42	42	0	37	41	0	0	0	0	0	42	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		5/01/2026	5/02/2026	3/03/2026	6/04/2026	7/05/2026	1/06/2026	1/07/2026	-	-	-	-	-		*"-" indicates no Unit run for reporting period*		
Date Data Published		5/01/2026	5/02/2026	3/03/2026	6/04/2026	7/05/2026	1/06/2026	1/07/2026	-	-	-	-	-				