Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
Environment Protection Licence Number - 12490
Pollution Monitoring - Nitrogen Oxides

REPORTING PERIOD 1 DEC 24 - 30 NOV 25

Sample Location	Data Sort	Dec-24	Jan-25	Feb-25	Mar-25	Apr-25	May-25	Jun-25	Jul-25	Aug-25	Sep-25	Oct-25	Nov-25	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	27	30	33	21	21	27	27	27	28	29	27	27	27	mg/m3	-	-
EPA Identification No. 1	Minimum	7	20	21	7	8	9	10	11	12	13	8	8	7	mg/m3	-	-
Unit 11	Maximum	49	45	50	33	38	46	50	42	40	43	50	14	50	mg/m3	51	100
Sample Point:	Average	27	30	25	25	25	25	26	26	26	27	28	24	26	mg/m3	-	-
EPA Identification No. 2	Minimum	6	21	17	7	7	9	9	10	10	9	8	8	6	mg/m3	-	-
Unit 12	Maximum	45	43	42	30	43	43	41	45	37	43	44	44	50	mg/m3	51	100
Sample Point:	Average	26	29	27	24	23	23	24	26	26	26	25	27	26	mg/m3	-	-
EPA Identification No. 3	Minimum	7	22	11	7	7	8	8	8	9	8	8	8	7	mg/m3	-	-
Unit 13	Maximum	48	45	43	34	37	39	43	46	40	44	43	44	48	mg/m3	51	100
Sample Point:	Average	28	27	25	20	20	26	25	26	26	28	26	28	26	mg/m3	-	-
EPA Identification No. 4	Minimum	7	22	9	6	6	7	8	8	9	13	7	8	6	mg/m3	-	-
Unit 14	Maximum	41	45	37	34	40	38	34	41	36	39	43	41	45	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		5/03/2025	5/03/2025	5/03/2025	5/06/2025	5/06/2025	5/06/2025	10/08/2025	10/08/2025	10/08/2025	10/08/2025	10/12/2025	10/12/2025		*"-" indicates no Unit run for reporting period*		
Date Data Published		5/03/2025	5/03/2025	5/03/2025	5/06/2025	5/06/2025	5/06/2025	10/08/2025	10/08/2025	10/08/2025	10/08/2025	10/12/2025	10/12/2025				