Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
Environment Protection Licence Number - 12490
Pollution Monitoring - Nitrogen Oxides

REPORTING PERIOD 1 DEC 21 - 30 NOV 22

Sample Location	Data Sort	Dec-21	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Jun-22	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	30	0	22	39	0	0	26	27	28	31	28	28	22	mg/m3	-	-
EPA Identification No. 1	Minimum	24	0	8	32	0	0	22	3	18	29	1	24	0	mg/m3	-	-
Unit 11	Maximum	48	0	50	49	0	0	49	51	51	44	49	35	51	mg/m3	51	100
Sample Point:	Average	36	31	30	31	26	33	29	32	32	35	29	26	31	mg/m3	-	-
EPA Identification No. 2	Minimum	31	27	6	27	7	27	8	27	27	29	28	14	6	mg/m3	-	-
Unit 12	Maximum	50	50	49	41	49	40	0	0	0	0	42	38	50	mg/m3	51	100
Sample Point:	Average	28	24	24	27	22	35	27	29	28	28	23	25	27	mg/m3	-	-
EPA Identification No. 3	Minimum	22	19	6	22	9	25	12	9	23	25	6	22	6	mg/m3	-	-
Unit 13	Maximum	47	41	46	39	49	50	50	44	47	40	51	45	51	mg/m3	51	100
Sample Point:	Average	30	24	25	28	25	28	28	0	28	27	24	24	24	mg/m3	-	-
EPA Identification No. 4	Minimum	21	0	0	18	7	7	0	0	24	14	14	10	0	mg/m3	-	-
Unit 14	Maximum	50	44	41	50	43	49	51	0	47	51	44	36	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		1/01/2022	1/02/2022	1/03/2022	1/04/2022	1/05/2022	1/06/2022	1/07/2022	1/08/2022	1/09/2022	1/10/2022	1/11/2022	1/12/2022		*"-" indicates no Unit run for reporting period*		
Date Data Published		20/07/2022	20/07/2022	20/07/2022	20/07/2022	20/07/2022	20/07/2022	20/07/2022	10/01/2023	10/01/2023	10/01/2023	10/01/2023	10/01/2023				