Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
Environment Protection Licence Number - 12490
Pollution Monitoring - Nitrogen Oxides

REPORTING PERIOD 1 DEC 20 - 30 NOV 21

Sample Location	Data Sort	Dec-19	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	30	42	0	27	30	32	28	25	25	29	0	19	24	mg/m3	-	-
EPA Identification No. 1	Minimum	9	39	0	10	25	10	19	19	19	26	0	6	0	mg/m3	-	-
Unit 11	Maximum	50	51	0	51	50	51	51	51	51	49	0	44	51	mg/m3	51	100
Sample Point:	Average	29	42	0	28	30	29	30	30	29	30	34	24	28	mg/m3	-	-
EPA Identification No. 2	Minimum	9	41	0	9	26	8	24	18	11	5	19	6	0	mg/m3	-	-
Unit 12	Maximum	50	50	49	41	49	40	0	0	0	0	46	48	50	mg/m3	51	100
Sample Point:	Average	27	35	0	22	25	26	27	26	26	26	0	24	22	mg/m3	-	-
EPA Identification No. 3	Minimum	7	28	0	4	18	7	11	4	5	20	0	7	0	mg/m3	-	-
Unit 13	Maximum	50	38	0	44	47	48	45	50	45	47	0	51	51	mg/m3	51	100
Sample Point:	Average	26	40	0	29	33	32	33	33	33	29	0	21	26	mg/m3	-	-
EPA Identification No. 4	Minimum	9	37	0	12	28	9	26	0	0	0	0	5	0	mg/m3	-	-
Unit 14	Maximum	51	51	0	48	50	51	50	51	49	51	0	47	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		3/01/2021	5/02/2021	1/07/2021	1/07/2021	1/07/2021	1/07/2021	1/07/2021	8/12/2021	8/12/2021	8/12/2021	8/12/2021	1/12/2020		*"-" indicates no Unit run for reporting period*		
Date Data Published		10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022	10/01/2022				